

LEGEND	
SYMBOL	DESCRIPTION
	FAN COIL UNIT
	1200x600mm REUTRN AIR GRILLE C/W ALUMINUM FILTER
	200mm (H) SUPPLY AIR GRILLE C/W DOUBLE DEFLECTION
	600x600mm 4-WAYS SUPPLY AIR GRILLE C/W VCD
	CHILLED WATER PIPE
	CONDENSATE DRAIN PIPE
	WALL MOUNT DUCT TYPE THERMOSTAT C/W DIGITAL DISPLAY
	250 1/2 DUCT TYPE CEILING MOUNT EXHAUST FAN
"XX" REFER TO THE BELOW ABBREVIATIONAS FOR INSTALLATION LEVEL	
FCU-EX-T1	EXISTING LARGER SIZE FCU
FCU-EX-T2	EXISTING MIDDLE SIZE FCU
FCU-EX-T3	EXISTING SMALL SIZE FCU

REMARKS

1. EXISTING HAVE DIFFERENT TYPE OF FAN COIL UNIT, THE CONTRACTOR IS REQUIRED TO VERIFY THE MODEL AND DO THE FUNCTIONAL CHECK BEFORE SITE WORK STARTED.

2. THE CONTRACTOR IS REQUIRED TO VERIFY THE ACTUAL LOCTION & ROUTE OF ALL MEP RELATED SERVICES ON SITE. ANY DISCREPANCY FOUND BETWEEN THE DRAWINGS AND ACTUAL SITE CONDITIONS MUST BE SUBMITTED FOR APPROVAL PRIOR TO COMMENCEMENT OF WORK. ANY CLAIMS ON WORK DONE WITHOUT PRIOR APPROVAL WILL NOT BE ACCEPTED AND AT THE CONTRACTOR'S OWN RISK.

